



Legislation Details (With Text)

File #: RLH FOW 12-180 **Version:** 2

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 7/3/2012

Title: Appeal of Tony Swanson, on behalf of Public Housing Agency of St. Paul, to a Fire Inspection Correction Notice at 805 CARROLL AVENUE.

Sponsors: Melvin Carter III

Indexes: Fire C of O Letter, Ward - 1, Windows

Code sections:

Attachments: 1. 805 Carroll.appeal.5-11-12.pdf, 2. 805 Carroll Ave.PHA Ltr 6-13-12.pdf

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/5/2012	1	Legislative Hearings	Referred	

Appeal of Tony Swanson, on behalf of Public Housing Agency of St. Paul, to a Fire Inspection Correction Notice at 805 CARROLL AVENUE.

#3 Double hung windows - request variance on openable height.

April 20, 2012

Rick Gavin

No hearing necessary.

Yes, 1 inch egress opening height for listed windows.

WHEREAS, in the matter of the Appeal of Tony Swanson, on behalf of Public Housing Agency of St. Paul, to a Fire Inspection Correction Notice at 805 CARROLL AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable height of the egress windows in the northeast, northwest and southwest bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.