



## Legislation Details (With Text)

**File #:** RLH FOW 12-208 **Version:** 2  
**Type:** Resolution LH Fire Ordered Windows **Status:** Passed  
**In control:** City Council  
**Final action:** 7/3/2012  
**Title:** Appeal of Kent Peterson to a Fire Inspection Correction Notice at 816 ASHLAND AVENUE.  
**Sponsors:** Melvin Carter III  
**Indexes:** Fire C of O Letter, Ward - 1, Windows  
**Code sections:**  
**Attachments:** 1. 816 Ashland.appeal.5-24-12, 2. 816 Ashland Ave.Peterson Ltr 6-18-12.pdf

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/12/2012	1	Legislative Hearings	Referred	

Appeal of Kent Peterson to a Fire Inspection Correction Notice at 816 ASHLAND AVENUE.

Windows

May 18, 2012

Michael Efferson

No hearing necessary.

Yes, upper unit - 7 inches egress opening height.

WHEREAS, in the matter of the Appeal of Kent Peterson to a Fire Inspection Correction Notice at 816 ASHLAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of the egress bedroom window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.