City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #:	RLH FOW 12-189 **Version:** 2		
Type:	Resolution LH Fire Ordered Windows	**Status:**	Passed
		In control:	City Council
		Final action:	7/3/2012
Title:	Appeal of Arta Cheney to a Fire Certificate of Occupancy Inspection Correction Notice at 808 PASCAL STREET NORTH.		
Sponsors:	Russ Stark		
Indexes:	Fire C of O Letter, Ward - 4, Windows		
Code sections:			
Attachments:	1. 808 Pascal.appeal.5-14-12.pdf, 2. 808 Pascal St N.Cheney Ltr 6-13-12.pdf		

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/5/2012	1	Legislative Hearings	Referred	

Appeal of Arta Cheney to a Fire Certificate of Occupancy Inspection Correction Notice at 808 PASCAL STREET NORTH.

Bedroom windows failed minimum opening.

May 4, 2012

Mitchell Imbertson

No hearing necessary.

Yes, front bedroom - 6.5 inches egress opening height and rear bedroom 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Arta Cheney to a Fire Certificate of Occupancy Inspection Correction Notice at 808 PASCAL STREET NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council Grant a 6-inch variance on the openable height of the egress window in the front bedroom lower unit; grant a 3-inch varaince on the openable height of the egress window in the rear bedroom lower unit; and grant a 6.5-inch variance on the openable height of the egress window in the upper unit bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

powered by Legistar™