



## Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-242

**Type:** Resolution LH Fire Ordered Windows      **Status:** Passed

**In control:** City Council

**Final action:** 7/18/2012

**Title:** Appeal of Hong Yang to a Fire Inspection Correction Notice (windows only) at 645 GOTZIAN STREET.

**Sponsors:** Kathy Lantry

**Indexes:** Fire C of O Letter, Ward - 7, Windows

**Code sections:**

**Attachments:** 1. 645 Gotzian St.appeal.6-11-12, 2. 645 Gotzian St.Yang Ltr 6-21-12.pdf

Date	Ver.	Action By	Action	Result
7/24/2012	2	Mayor's Office	Signed	
7/18/2012	2	City Council	Adopted	Pass
6/19/2012	1	Legislative Hearings	Referred	

Appeal of Hong Yang to a Fire Inspection Correction Notice (windows only) at 645 GOTZIAN STREET.

Deficiency #1 - Window in the west bedroom on the 2nd floor measured H 21.5in, W 27 in., glazed area H 49 in. W 23.5 in.

The code requirement for the window is H 24 in.

May 10, 2012

Mike Cassidy

No hearing necessary.

Yes, 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Hong Yang to a Fire Inspection Correction Notice at 645 GOTZIAN STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress window in the second floor west bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.