



Legislation Details (With Text)

File #: RLH WP 12- 73 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 7/18/2012

Title: Appeal of Daniel Englund, Jr. to an Egress Window Non-Compliance Determination at 1640 ROSS AVENUE.

Sponsors: Kathy Lantry

Indexes: Ward - 7, Windows

Code sections:

Attachments: 1. 1640 Ross Ave.appeal.6-18-12.pdf, 2. 1640 Ross Ave.Englund ltr 6-27-12.pdf

Date	Ver.	Action By	Action	Result
7/24/2012	2	Mayor's Office	Signed	
7/18/2012	2	City Council	Adopted	Pass
6/26/2012	1	Legislative Hearings	Referred	

Appeal of Daniel Englund, Jr. to an Egress Window Non-Compliance Determination at 1640 ROSS AVENUE.

Only egress windows

June 13, 2012

David Nelson

No hearing necessary.

Yes, 7 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Englund, Jr. to an Egress Window Non-Compliance Determination at 1640 ROSS AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of one double hung replacement egress bedroom window measuring 17 inches high by 24 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.