



Legislation Details (With Text)

File #: RLH WP 12- 63 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 7/18/2012

Title: Appeal of Molly McGrane, Window World, to an Egress Window Non-Compliance Determination at 905 WHITE BEAR AVENUE NORTH.

Sponsors: Dan Bostrom

Indexes: Ward - 6, Windows

Code sections:

Attachments: 1. 905 White Bear Ave.N.appeal 6-01-12, 2. 905 White Bear Ave N.Window World Ltr 6-21-12.pdf

Date	Ver.	Action By	Action	Result
7/24/2012	2	Mayor's Office	Signed	
7/18/2012	2	City Council	Adopted	Pass
6/19/2012	1	Legislative Hearings	Referred	

Appeal of Molly McGrane, Window World, to an Egress Window Non-Compliance Determination at 905 WHITE BEAR AVENUE NORTH.

Windows

May 8, 2011

David Nelson

No hearing necessary. Note condition listed below has been met, per DSI staff.

Yes, 6 inches minimum sill height, on condition that at least 1 standard dimension step for length of window.

WHEREAS, in the matter of the Appeal of Molly McGrane, Window World, to an Egress Window Non-Compliance Determination at 905 WHITE BEAR AVENUE NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the sill height provided the owner installs steps below the egress windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.