



Legislation Details (With Text)

File #: RLH WP 12- 70 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 7/18/2012

Title: Appeal of Daniel Schmidt, Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 979 LAWSON AVENUE.

Sponsors: Dan Bostrom

Indexes: Ward - 6, Windows

Code sections:

Attachments: 1. 979 Lawson Ave.appeal.6-6-12, 2. 979 Lawson Ave.Public Health Ltr 6-21-12.pdf

Date	Ver.	Action By	Action	Result
7/24/2012	2	Mayor's Office	Signed	
7/18/2012	2	City Council	Adopted	Pass
6/19/2012	1	Legislative Hearings	Referred	

Appeal of Daniel Schmidt, Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 979 LAWSON AVENUE.

Windows

June 6, 2012

None listed.

No hearing necessary.

Yes, 4.5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 979 LAWSON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 19.87 inches high by 27 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.