



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-250

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 7/18/2012

Title: Appeal of Home Sweet Home to a Fire Certificate of Occupancy Inspection Correction Notice at 837 JESSAMINE AVENUE EAST.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 837 Jessamine Ave E.appeal.6-15-12.pdf, 2. 837 Jessamine Ave E.Bohlen ltr 6-29-12.pdf

Date	Ver.	Action By	Action	Result
7/24/2012	2	Mayor's Office	Signed	
7/18/2012	2	City Council	Adopted	Pass
6/26/2012	1	Legislative Hearings	Referred	

Appeal of Home Sweet Home to a Fire Certificate of Occupancy Inspection Correction Notice at 837 JESSAMINE AVENUE EAST.

Item #5 and Item #9 on deficiency list - southwest (Unit #1) bedroom window exits into front porch. Unit #2 northwest & southwest bedroom windows - double hung 20 X 19.

June 6, 2012

Benjamin Ellis

Need more info on where the window in unit 1 discharges to.

Yes, Unit 2 - 4 inches egress opening height and 1 inch egress opening width and Unit 1 - ??

WHEREAS, in the matter of the Appeal of Home Sweet Home to a Fire Certificate of Occupancy Inspection Correction Notice at 837 JESSAMINE AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal and grant an extension to October 1, 2012 for compliance; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.