



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Details (With Text)

**File #:** RLH FOW 12-235 **Version:** 2  
**Type:** Resolution LH Fire Ordered Windows **Status:** Passed  
**In control:** City Council  
**Final action:** 7/18/2012  
**Title:** Appeal of Scott Spiess to a Fire Inspection Correction Notice (windows only) at 1412 TAYLOR AVENUE.  
**Sponsors:** Russ Stark  
**Indexes:** Fire C of O Letter, Ward - 4, Windows  
**Code sections:**  
**Attachments:** 1. 1412 Taylor Ave.appeal.6-4-12, 2. 1412 Taylor Ave.Spiess Ltr 6-21-12.pdf

Date	Ver.	Action By	Action	Result
7/24/2012	2	Mayor's Office	Signed	
7/18/2012	2	City Council	Adopted	Pass
6/19/2012	1	Legislative Hearings	Referred	

Appeal of Scott Spiess to a Fire Inspection Correction Notice (windows only) at 1412 TAYLOR AVENUE.

Short by 4 inches with 27 inches wide, 6.7 sq. ft. total.

May 23, 2012

Mitchell Imbertson

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Scott Spiess to a Fire Inspection Correction Notice (windows only) at 1412 TAYLOR AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress window in the second floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.