



## Legislation Details (With Text)

**File #:** RLH WP 12- 65 **Version:** 2  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 7/18/2012  
**Title:** Appeal of Renewal by Andersen, on behalf of Thomas Barnes, to an Egress Window Non-Compliance Determination at 1236 EDGCUMBE ROAD.  
**Sponsors:** Chris Tolbert  
**Indexes:** Ward - 3, Windows  
**Code sections:**  
**Attachments:** 1. 1236 Edgcumbe.appeal.6-11-12.pdf, 2. 1236 Edgcumbe Rd.Renewal by Andersen ltr 6-27-12.pdf

| Date      | Ver. | Action By            | Action   | Result |
|-----------|------|----------------------|----------|--------|
| 7/24/2012 | 2    | Mayor's Office       | Signed   |        |
| 7/18/2012 | 2    | City Council         | Adopted  | Pass   |
| 6/26/2012 | 1    | Legislative Hearings | Referred |        |

Appeal of Renewal by Andersen, on behalf of Thomas Barnes, to an Egress Window Non-Compliance Determination at 1236 EDGCUMBE ROAD.

2 replacement windows will not meet egress policy. Sizes attached. Please approve.

May 30, 2012

REHN

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Renewal by Andersen, on behalf of Thomas Barnes, to an Egress Window Non-Compliance Determination at 1236 EDGCUMBE ROAD; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5inch variance on the openable height of two double hung replacement egress bedroom windows measuring 19-7/8 inches high by 25 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.