



Legislation Details (With Text)

File #: RLH WP 12- 68 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 7/18/2012
Title: Appeal of Daniel Schmidt, Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 155 BAKER STREET WEST.
Sponsors: Dave Thune
Indexes: Ward - 2, Windows
Code sections:
Attachments: 1. 155 Baker St. W.appeal.6-6-12, 2. 155 Baker St W.Public Health Ltr 6-21-12.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|----------------------|----------|--------|
| 7/24/2012 | 2 | Mayor's Office | Signed | |
| 7/18/2012 | 2 | City Council | Adopted | Pass |
| 6/19/2012 | 1 | Legislative Hearings | Referred | |

Appeal of Daniel Schmidt, Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 155 BAKER STREET WEST.

Windows

June 6, 2012

None listed.

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 155 BAKER STREET WEST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 22.06 inches high by 27 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.