



Legislation Details (With Text)

File #: RLH WP 12- 72 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 7/18/2012
Title: Appeal of Daniel Schmidt, Saint Paul-Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 144 CURTICE STREET EAST.
Sponsors: Dave Thune
Indexes: Ward - 2, Windows
Code sections:
Attachments: 1. 144 Curtice St.appeal.6-14-12.pdf, 2. 144 Curtice St E.Public Health ltr 6-27-12.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|----------------------|----------|--------|
| 7/24/2012 | 2 | Mayor's Office | Signed | |
| 7/18/2012 | 2 | City Council | Adopted | Pass |
| 6/26/2012 | 1 | Legislative Hearings | Referred | |

Appeal of Daniel Schmidt, Saint Paul-Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 144 CURTICE STREET EAST.

(Windows)

June 14, 2012

Unknown

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, Saint Paul-Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 144 CURTICE STREET EAST; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of one double hung replacement egress bedroom window measuring 20-inches high by 25.2 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.