



Legislation Details (With Text)

File #: RLH FCO 12- **Version:** 3
335

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 7/18/2012

Title: Appeal of WYYC Property Management, on behalf of Gin and Olivia Ng, to a Fire Certificate of Occupancy Inspection Correction Notice at 755 SHERBURNE AVENUE. (Public hearing continued from June 20)

Sponsors: Melvin Carter III

Indexes: Fire C of O Letter, Ward - 1, Windows

Code sections:

Attachments: ,

Date	Ver.	Action By	Action	Result
7/24/2012	3	Mayor's Office	Signed	
7/18/2012	3	City Council	Adopted	Pass
7/10/2012	2	Legislative Hearings	Referred	
6/20/2012	2	City Council	Referred	Pass
5/22/2012	1	Legislative Hearings	Referred	

Appeal of WYYC Property Management, on behalf of Gin and Olivia Ng, to a Fire Certificate of Occupancy Inspection Correction Notice at 755 SHERBURNE AVENUE.

Ceiling height in basement bedrooms
Upper front bedroom (north) double hung

April 19, 2012

Williem Beumer

No hearing necessary.

Yes, 4 inches egress opening height for 2nd floor north bedroom window and 4 inches minimum ceiling height in basement.

WHEREAS, in the matter of the Appeal of WYYC Property Management, on behalf of Gin and Olivia Ng, to a Fire Certificate of Occupancy Inspection Correction Notice at 755 SHERBURNE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress window in the second floor north bedroom; grant a 4-inch variance on the ceiling height issue in the basement north bedroom; deny a 9-inch variance on the hall basement ceiling height and grant 90 days for compliance or the basement will need to be vacated; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.