



## Legislation Details (With Text)

**File #:** RLH FOW 12-244 **Version:** 2

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 7/18/2012

**Title:** Appeal of Four Corners Properties of Minnesota LLC to a Fire Inspection Correction Notice at 814 ENGLEWOOD AVENUE.

**Sponsors:** Melvin Carter III

**Indexes:** Fire C of O Letter, Ward - 1, Windows

**Code sections:**

**Attachments:** 1. 814 Englewood Ave.appeal.6-12-12, 2. 814 Englewood Ave.Four Corners ltr 6-28-12.pdf

Date	Ver.	Action By	Action	Result
7/24/2012	2	Mayor's Office	Signed	
7/18/2012	2	City Council	Adopted	Pass
6/26/2012	1	Legislative Hearings	Referred	

Appeal of Four Corners Properties of Minnesota LLC to a Fire Inspection Correction Notice at 814 ENGLEWOOD AVENUE.

Windows - see attachment

June 5, 2012

Lisa Martin

WHEREAS, in the matter of the Appeal of Four Corners Properties of Minnesota LLC to a Fire Inspection Correction Notice at 814 ENGLEWOOD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1 inch variance on the openable width and a 2 inch variance on the openable height of the egress windows in the upstairs bedrooms - noting that no variance is necessary if windows are not stuck; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.