



Legislation Details (With Text)

File #: RLH FCO 12- 422 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 8/1/2012
Title: Appeal of JoAnn Donley to a Fire Inspection Correction Notice at 2010 HAWTHORNE AVENUE EAST.
Sponsors: Dan Bostrom
Indexes: Fire C of O Letter, Ward - 6
Code sections:
Attachments: 1. 2010 Hawthorne Ave.appeal.6-20-12, 2. 2010 Hawthorne Ave E.Donley Ltr 7-11-12.pdf

Date	Ver.	Action By	Action	Result
8/8/2012	2	Mayor's Office	Signed	
8/1/2012	2	City Council	Adopted	Pass
7/10/2012	1	Legislative Hearings	Referred	

Appeal of JoAnn Donley to a Fire Inspection Correction Notice at 2010 HAWTHORNE AVENUE EAST.

#1 - They are the original sized windows. I lived there my childhood, no problems, family home for 50+ years

June 12, 2010

James Thomas

Hearing on the balance.

Yes. 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of JoAnn Donley to a Fire Inspection Correction Notice at 2010 HAWTHORNE AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress windows in all bedrooms; deny the appeal on the heating and garage issues and grant until October 1, 2012 for compliance; and grant until August 1, 2012 for the other items on the list; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.