



Legislation Details (With Text)

File #: RLH FCO 12- Version: 2
468

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 9/19/2012

Title: Appeal of Binh Le to a Fire Certificate of Occupancy Correction Notice at 869 BEECH STREET (Ceiling Height).

Sponsors: Kathy Lantry

Indexes: Fire C of O Letter, Ward - 7

Code sections:

Attachments: 1. 869 Beech St.appeal.7-11-12.pdf, 2. 869 Beech St.Le Ltr 8-22-12.pdf, 3. 869 Beech St.Le Ltr 8-6-12.pdf, 4. 869 Beech St Le Ltr 8-9-12.pdf, 5. 869 Beech.Photos.7-17-12.pdf

Date	Ver.	Action By	Action	Result
9/25/2012	2	Mayor's Office	Signed	
9/19/2012	2	City Council	Adopted	Pass
8/14/2012	1	Legislative Hearings	Referred	
8/7/2012	1	Legislative Hearings	Laid Over	
7/17/2012	1	Legislative Hearings	Laid Over	

Appeal of Binh Le to a Fire Certificate of Occupancy Correction Notice at 869 BEECH STREET (Ceiling Height).

House was built in 1909, bedroom in upper floor and basement are non conforming. Those are the only two bedrooms in the house. Height is 80 in. and 79.73 inc. respectively; required height is 84 in. Also, the window was built at the same time when the house was constructed. We ask politely to have the window stay in tact as it adds a lot of charm to the house.

June 18, 2012

Wayne Spiering

Hearing necessary on the balance of the appeal.

Yes, upper floor west bedroom - 4 inches minimum ceiling height; basement bedroom - 5 inches minimum ceiling height (note area of room at 6'1" is less than 50% of square footage, and upper floor southeast bedroom - 3 inches minimum ceiling height (however, no variance recommended on room size).

WHEREAS, in the matter of the Appeal of Binh Le to a Fire Certificate of Occupancy Correction Notice at 869 BEECH STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal on the upstairs and basement ceiling heights; deny on the driveway and garage exterior and grant an extension to November

1, 2012 for compliance; deny on the basement steps landing and basement cannot be used for sleeping purposes; upper floor southeast bedroom cannot be used as a sleeping area; and deny on the remaining items and grant an extension to September 1, 2012 for compliance; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.