



Legislation Details (With Text)

File #: RLH FCO 12- **Version:** 2
645

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 1/2/2013

Title: Appeal of Iglesia Cedros Del Libano to a Fire Inspection Correction Notice at 1003 ARCADE STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6

Code sections:

Attachments: 1. 1003 Arcade St.appeal.12-03-12, 2. 1003 Arcade St.Fire Order.12-3-12, 3. 1003 Arcade Street Ltr 12-17-12

Date	Ver.	Action By	Action	Result
1/4/2013	2	Mayor's Office	Signed	
1/2/2013	2	City Council	Adopted	Pass
12/11/2012	1	Legislative Hearings	Referred	

Appeal of Iglesia Cedros Del Libano to a Fire Inspection Correction Notice at 1003 ARCADE STREET.

We would like to appeal the case of the last fire inspection we had last month November 19, '12. There were few things that we would like to talk about.

November 20, 2012

Sebastian Migdal

WHEREAS, in the matter of the Appeal of Iglesia Cedros Del Libano to a Fire Inspection Correction Notice at 1003 ARCADE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal and grant an extension to April 1, 2013 to install panic hardware on the door that goes out from the vestibule and provide signage in both English and Spanish indicating it is not an exit. All other items are to be in compliance by January 4, 2013.; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.