



Legislation Details (With Text)

File #: RLH FCO 13- 32 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 2/20/2013
Title: Appeal of Ying Vang to a Fire Certificate of Occupancy Correction Notice at 842 JENKS AVENUE.
Sponsors: Dan Bostrom
Indexes: Fire C of O Letter, Ward - 6
Code sections:
Attachments: 1. 842 Jenks Ave.appeal.1-18-13, 2. 842 Jenks Ave.Vang Ltr 1-30-13

Date	Ver.	Action By	Action	Result
2/25/2013	2	Mayor's Office	Signed	
2/20/2013	2	City Council	Adopted	Pass
1/29/2013	1	Legislative Hearings	Referred	

Appeal of Ying Vang to a Fire Certificate of Occupancy Correction Notice at 842 JENKS AVENUE.

Item 3 - Provide a grounding jumper around the water meter.

January 7, 2013

Brian Tonnancour

WHEREAS, in the matter of the Appeal of Ying Vang to a Fire Certificate of Occupancy Correction Notice at 842 JENKS AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal and grant until March 1, 2013 to address the grounding jumper around the water meter; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.