



Legislation Details (With Text)

File #: RLH FCO 13- 62 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 4/17/2013
Title: Appeal of Michael Koch to a Fire Inspection Correction Notice at 1611 SPRUCE TREE DRIVE.
Sponsors: Russ Stark
Indexes: Fire C of O Letter, Ward - 4
Code sections:
Attachments: 1. 1611 Spruce Tree Dr.appeal.3-06-13, 2. 1611 Spruce Tree Ave.Photos.3-1-13, 3. 1611 Spruce Tree Ave.Ramp Renovation Plan.3-18-13, 4. 1611 Spruce Tree Ave.Compliance Alternative Options.3-18-13, 5. 1611 Spruce Tree Dr.Koch Ltr.3-22-13

Date	Ver.	Action By	Action	Result
4/23/2013	2	Mayor's Office	Signed	
4/17/2013	2	City Council	Adopted	Pass
3/19/2013	1	Legislative Hearings	Referred	

Appeal of Michael Koch to a Fire Inspection Correction Notice at 1611 SPRUCE TREE DRIVE.

We request a variance or alternative way of compliance with Items 1, 3, 6 and 8.

February 25, 2013

Sebastian Migdal

WHEREAS, in the matter of the Appeal of Michael Koch to a Fire Inspection Correction Notice at 1611 SPRUCE TREE DRIVE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an extension for 60 days to install delay emergency exit hardware as an alternative means of compliance which will be monitored by AnswerNet when the building is closed; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.