

## City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

## Legislation Details (With Text)

File #: RLH FCO 13- Version: 2

66

Type: Resolution LH Fire C of O OR Status:

Correction Order

In control: City Council

Passed

**Final action:** 6/5/2013

**Title:** Appeal of Gidget Bailey, Tin Cups, to a Re-inspection Fire Certificate of Occupancy with Deficiencies

at 1220 RICE STREET.

**Sponsors:** Amy Brendmoen

**Indexes:** Fire C of O Letter, Ward - 5

Code sections:

Attachments: 1. 1220 Rice St.appeal.3-14-13, 2. 1220 Rice St.Bailey Ltr.3-22-13, 3. 1220 Rice St.1319 - Tin Cup's

Restaurant Diagram.4-11-13, 4. 1220 Rice St.Floor Plan with Notes.5-2-13, 5. 1220 Rice St.Letter 4-11-13, 6. 1220 Rice St,Tin Cups Basement Diagram w Modifications.5-5-13, 7. 1220 Rice St.Letter 5-

13-13

Date	Ver.	Action By	Action	Result
6/7/2013	2	Mayor's Office	Signed	
6/5/2013	2	City Council	Adopted As Amended	Pass
5/7/2013	1	Legislative Hearings	Referred	
4/9/2013	1	Legislative Hearings	Laid Over	
3/19/2013	1	Legislative Hearings	Laid Over	

Appeal of Gidget Bailey, Tin Cups, to a Re-inspection Fire Certificate of Occupancy with Deficiencies at 1220 RICE STREET.

They are saying that I have to much square footage for 49 people in the basement.

February 15, 2013

Kris Skow-Fiske

Pictures and/or a diagram of the basement would be usedul.

## **AMENDED 6/5/13**

WHEREAS, in the matter of Gidget Bailey, Tin Cups, to a Re-inspection Fire Certificate of Occupancy with Deficiencies at 1220 RICE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a variance allowing the space to be used with only one exit, due to substantial decrease in usable floor area with the addition of the permanent serving area to be effectuated by July 15, 2013; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's

File #: RLH FCO 13-66, Version: 2

recommendation in this matter.