



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FCO 13- 105 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 6/5/2013
Title: Appeal of Nikolai Alenov to a Fire Inspection Correction Notice at 1756 UNIVERSITY AVENUE WEST.
Sponsors: Russ Stark
Indexes: Correction Order, Ward - 4
Code sections:
Attachments: 1. 1756 University Ave W.appeal.5-2-13, 2. 1756 University Ave W.City Photos.5-13-13, 3. 1756 University Ave W.Owner Photos.5-14-13, 4. 1756 University Ave W.alenov Ltr.5-16-13

Date	Ver.	Action By	Action	Result
6/7/2013	2	Mayor's Office	Signed	
6/5/2013	2	City Council	Adopted	Pass
5/14/2013	1	Legislative Hearings	Referred	

Appeal of Nikolai Alenov to a Fire Inspection Correction Notice at 1756 UNIVERSITY AVENUE WEST.

Ref #13708 Number 3. Back steps. Back steps are only used by me and not a public entrance. Would make it difficult to unload my supplies and shovel snow. It has a hand railing and is under 30 inches at the top of the steps.

April 23, 2013

Kris Skow-Fiske

WHEREAS, in the matter of Nikolai Alenov to a Fire Inspection Correction Notice at 1756 UNIVERSITY AVENUE WEST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal for the next two years to continue current use without installing a guardrail. If there is a change in ownership or a change of use, the guardrail will need to be installed; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.