



Legislation Details (With Text)

File #: RLH FCO 13- 221 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 10/16/2013
Title: Appeal of Art Harder to a Fire Inspection Correction Notice at 284 SHERBURNE AVENUE.
Sponsors: Nathaniel Khaliq
Indexes: Fire C of O Letter, Ward - 1
Code sections:
Attachments: 1. 284 Sherburne.appeal.9-25-13, 2. 284 Sherburne.Photos.9-16-13, 3. 284 Sherburne Ave.Harder Ltr 10-2-13, 4. 284 Sherburne Ave. Harder Revised Letter.10-10-13

Date	Ver.	Action By	Action	Result
10/24/2013	2	Mayor's Office	Signed	
10/16/2013	2	City Council	Adopted	Pass
10/1/2013	1	Legislative Hearings	Referred	

Appeal of Art Harder to a Fire Inspection Correction Notice at 284 SHERBURNE AVENUE.

SPLC 34.08 (7) Parking Surfaces. Inspector suggested it. Plus it has nothing to do with health and safety. It's arbitrary and selectively enforced. The driveway is dust free.

September 16, 2013

Jeremy Hall

WHEREAS, in the matter of Appeal of Art Harder to a Fire Inspection Correction Notice at 284 SHERBURNE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant until December 1, 2013 to install a 4-inch bollard to protect the gas meter and grant until June 1, 2014 to bring the driveway into compliance by adding more Class 5 and make clean lines to create boundaries between the parking and gass, or in the alternative providing a cement "cowpath" drive; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.