



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FCO 13- 244 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 12/4/2013
Title: Appeal of Robert Johnson to a Fire Inspection Correction Notice at 276 EXCHANGE STREET SOUTH.
Sponsors: Dave Thune
Indexes: Fire C of O Letter, Ward - 2
Code sections:
Attachments: 1. 276 Exchange St S.appeal.11-4-13, 2. 276 Exchange St S.Johnson Ltr.11-14-13

Date	Ver.	Action By	Action	Result
12/11/2013	2	Mayor's Office	Signed	
12/4/2013	2	City Council	Adopted	Pass
11/12/2013	1	Legislative Hearings	Referred	

Appeal of Robert Johnson to a Fire Inspection Correction Notice at 276 EXCHANGE STREET SOUTH.

Sprinkler in 2nd floor closet.

October 24, 2013

Kris Show-Fiske

WHEREAS, in the matter of Appeal of Robert Johnson to a Fire Inspection Correction Notice at 276 EXCHANGE STREET SOUTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal provided that no combustible materials are stored in the un-sprinkled closets; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.