



## Legislation Details (With Text)

**File #:** RLH FCO 13- 259 **Version:** 2  
**Type:** Resolution LH Fire C of O OR Correction Order **Status:** Passed  
**In control:** City Council  
**Final action:** 12/18/2013  
**Title:** Appeal of Linda McInerney to a Daycare Inspection Correction Notice at 66 FLANDRAU PLACE.  
**Sponsors:** Kathy Lantry  
**Indexes:** Day Care, Fire C of O Letter, Ward - 7, Windows  
**Code sections:**  
**Attachments:** 1. 66 Flandrau Place.appeal.11-25-13, 2. 66 Flandrau Pl.McInerney Ltr.12-5-13

Date	Ver.	Action By	Action	Result
12/23/2013	2	Mayor's Office	Signed	
12/18/2013	2	City Council	Adopted	Pass
12/3/2013	1	Legislative Hearings	Referred	

Appeal of Linda McInerney to a Daycare Inspection Correction Notice at 66 FLANDRAU PLACE.

Second Floor bedroom windows-Page 2 #8 of attachment. Fire inspection for opening of child day care. The 2nd floor will not be used for child day care purposes.

November 22, 2013

James Perucca

No hearing necessary.

Yes, 8 inches egress opening height for all second floor bedroom windows.

WHEREAS, in the matter of the Appeal of Linda McInerney to a Correction Notice-Reinspection Complaint at 66 FLANDRAU PLACE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance on the openable height of the egress windows in the second floor bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.