



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH WP 12- 82 **Version:** 2
Type: Resolution LH Window Permit **Status:** Archived
In control: Legislative Hearings
Final action: 8/1/2012
Title: Appeal of Saint Paul Ramsey County Department of Public Health to an Egress Window Non-Compliance Determination at 728 MANOMIN AVENUE.
Sponsors: Dave Thune
Indexes: Ward - 2, Windows
Code sections:
Attachments: 1. 728 Manomin Ave.appeal.6-27-12.pdf, 2. 728 Manomin Ave.Public Health Ltr 7-10-12.pdf

Date	Ver.	Action By	Action	Result
7/10/2012	1	Legislative Hearings	Referred	

Appeal of Saint Paul Ramsey County Department of Public Health to an Egress Window Non-Compliance Determination at 728 MANOMIN AVENUE.

(2 windows)

June 27, 2012

(unknown)

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Saint Paul Ramsey County Department of Public Health to an Egress Window Non-Compliance Determination at 728 MANOMIN AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 20 inches high by 23.2 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.