



## Legislation Details (With Text)

**File #:** RLH FOW 12-262 **Version:** 2

**Type:** Resolution LH Fire Ordered Windows **Status:** Archived

**In control:** Legislative Hearings

**Final action:** 8/1/2012

**Title:** Appeal of Robert Torning to a Fire Inspection Correction Notice at 996 BURGESS STREET.

**Sponsors:** Melvin Carter III

**Indexes:** Fire C of O Letter, Ward - 1, Windows

**Code sections:**

**Attachments:** 1. 996 Burgess St.appeal.6-21-12, 2. 996 Burgess St.Torning Ltr 7-10-12.pdf

Date	Ver.	Action By	Action	Result
7/10/2012	1	Legislative Hearings	Referred	

Appeal of Robert Torning to a Fire Inspection Correction Notice at 996 BURGESS STREET.

#3 - Unit 1 rear bedroom. Window is certainly large enough for a person to escape. Windows are nice newer vinyl - large and open easily

June 11, 2012

Sebastian Migdal

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Robert Torning to a Fire Inspection Correction Notice at 996 BURGESS STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5 inch variance on the openable height of the window in the rear bedroom, Unit 1; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.