



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Details (With Text)

**File #:** RLH FOW 12-265 **Version:** 2  
**Type:** Resolution LH Fire Ordered Windows **Status:** Archived  
**In control:** Legislative Hearings  
**Final action:** 8/1/2012  
**Title:** Appeal of Ying Chu-Yang-Heu to a Fire Certificate of Occupancy Inspection Correction Notice at 761 CASE AVENUE.  
**Sponsors:** Dan Bostrom  
**Indexes:** Fire C of O Letter, Ward - 6, Windows  
**Code sections:**  
**Attachments:** 1. 761 Case Ave.appeal.6-21-12.pdf, 2. 761 Case Ave.Yang Heu Ltr 7-10-12.pdf

Date	Ver.	Action By	Action	Result
7/10/2012	1	Legislative Hearings	Referred	

Appeal of Ying Chu-Yang-Heu to a Fire Certificate of Occupancy Inspection Correction Notice at 761 CASE AVENUE.

(Item 7, escape window)

June 5, 2012

Mike Cassidy

No hearing necessary.

Yes, 6 inches egress opening height.

WHEREAS, in the matter of the Appeal of Ying Chu-Yang-Heu to a Fire Certificate of Occupancy Inspection Correction Notice at 761 CASE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of the egress windows in the 2nd floor, northwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.