



Legislation Details (With Text)

File #: RLH FOW 12-274 **Version:** 2

Type: Resolution LH Fire Ordered Windows **Status:** Archived

In control: Legislative Hearings

Final action: 8/1/2012

Title: Appeal of Jim Sundberg to a Fire Inspection Correction Notice at 746 SIMON AVENUE.

Sponsors: Amy Brendmoen

Indexes: Fire C of O Letter, Ward - 5, Windows

Code sections:

Attachments: 1. 746 Simon Ave.appeal.6-25-12.pdf, 2. 746 Simon Ave.Sundberg Ltr 7-10-12.pdf

Date	Ver.	Action By	Action	Result
7/10/2012	1	Legislative Hearings	Referred	

Appeal of Jim Sundberg to a Fire Inspection Correction Notice at 746 SIMON AVENUE.

#7 on attached list - The window is 2" short on required height but 5" over on required width. This should be ample size for escape if needed.

June 6, 2012

Sebastian Migdal

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Jim Sundberg to a Fire Inspection Correction Notice at 746 SIMON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in Unit 1 bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.