



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-276

Type: Resolution LH Fire Ordered **Status:** Archived
Windows

In control: Legislative Hearings

Final action: 8/1/2012

Title: Appeal of Cheryl Barsten to a Correction Notice-Complaint Inspection at 915 HAWTHORNE AVENUE EAST.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 915 Hawthorne Ave E.appeal.7-10-12.pdf, 2. 915 Hawthorne Ave E.Barsten Ltr 7-10-12.pdf

Date	Ver.	Action By	Action	Result
7/10/2012	1	Legislative Hearings	Referred	

Appeal of Cheryl Barsten to a Correction Notice-Complaint Inspection at 915 HAWTHORNE AVENUE EAST.

Re: Property in the attached deficiency list - The expense of replacing windows would be a hardship for me. I will be operating my child care business in the basement. These windows are on the second level.

June 26, 2012

James Perucca

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Cheryl Barsten to a Correction Notice-Complaint Inspection at 915 HAWTHORNE AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in the two second story bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.