



Legislation Details (With Text)

File #: RLH FCO 14- **Version:** 2
1

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 2/5/2014

Title: Appeal of Steven Ambli, Lift Pro, to a Fire Inspection Correction Notice at 2554 COMO AVENUE.

Sponsors: Russ Stark

Indexes: Fire C of O Letter, Ward - 4

Code sections:

Attachments: 1. 2554 Como Ave.appeal.12-27-13, 2. 2554 Como Ave.Owner Photos.1-7-14, 3. 2554 Como Ave.Ambli Ltr.1-7-14

Date	Ver.	Action By	Action	Result
2/10/2014	2	Mayor's Office	Signed	
2/5/2014	2	City Council	Adopted	Pass
1/7/2014	1	Legislative Hearings	Referred	

Appeal of Steven Ambli, Lift Pro, to a Fire Inspection Correction Notice at 2554 COMO AVENUE.

We of Lift Pro are appealing storage height requirement. If enforced as is, it would place us in a hardship position to do business in this location. Seek other possible solutions.

December 17, 2013

Mitchell Imbertson

WHEREAS, in the matter of Appeal of Steven Ambli, Lift Pro, to a Fire Inspection Correction Notice at 2554 COMO AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant until March 3, 2014 to reduce the storage height of all stored materials to 12 feet high or less in Unit 7; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.