



Legislation Details (With Text)

File #: RLH FCO 15- **Version:** 2
52

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 5/20/2015

Title: Appeal of Alana Sasaki to a Fire Inspection Correction Notice at 1701 MARGARET STREET.

Sponsors: Bill Finney

Indexes: Fire C of O Letter, Ward - 7

Code sections:

Attachments: 1. 1701 Margaret St.appeal.4-8-15, 2. 1701 Margaret St.Sasaki Ltr.4-29-15, 3. 1701 Margaret St.Sasaki Ltr.5-13-15

Date	Ver.	Action By	Action	Result
5/26/2015	2	Mayor's Office	Signed	
5/20/2015	2	City Council	Adopted	Pass
4/28/2015	1	Legislative Hearings	Referred	

Appeal of Alana Sasaki to a Fire Inspection Correction Notice at 1701 MARGARET STREET.

2) Interior - SPLC 34.13 (1) Habitable ceiling height.

1) These steps are original when we bought the house. It is consistent w/ the neighborhood and other properties surrounding.

2) It is the natural construction of this older home. It is only short by a few inches. We ask for exemption please.

WHEREAS, in the matter of Appeal of Alana Sasaki to a Fire Inspection Correction Notice at 1701 MARGARET STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council withdraw Item #1 (guardrail), denies the appeal for a ceiling height variance on the upper level bedroom where the ceiling peaks at 6 feet and 7 inches and grants to October 1, 2015 for compliance; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.