

## City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

## Legislation Details (With Text)

File #: RLH FCO 15- Version: 2

160

Type: Resolution LH Fire C of O OR Status: Passed

Correction Order

In control: City Council

**Final action:** 8/19/2015

Title: Appeal of Davie Veit to a Fire Certificate of Occupancy Correction Notice at 1982 HAWTHORNE

**AVENUE EAST** 

**Sponsors:** Dan Bostrom

**Indexes:** Fire C of O Letter, Ward - 6

**Code sections:** 

**Attachments:** 1. 1982 Hawthorne Ave E.appeal.7-29-15, 2. 1982 Hawthorne Ave E.Photo Doc 1.7-16-15, 3. 1982

Hawthorne Ave E.Photo Doc 2.7-16-15, 4. 1982 Hawthorne Ave E.Owner Photos.8-4-15, 5. 1982

Hawthorne Ave E.Veit Ltr 8-6-15, 6. 1982 Hawthorne Ave E.Reinsberg Email.8-14-15

	Date	Ver.	Action By	Action	Result
•	8/20/2015	2	Mayor's Office	Signed	
	8/19/2015	2	City Council	Adopted As Amended	Pass
	8/4/2015	1	Legislative Hearings	Referred	

Appeal of Davie Veit to a Fire Certificate of Occupancy Correction Notice at 1982 HAWTHORNE AVENUE EAST

Emailed Steve Ubl and Gary Reinsberg 8/11/15 with question from hearing 8/14/15. MM

## **AMENDED 8/19/2015**

WHEREAS, in the matter of Appeal of Davie Veit to a Fire Certificate of Occupancy Correction Notice at 1982 HAWTHORNE AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer's recommendation is forthcoming grant the appeal regarding the flexible duct work in excess of 14 feet; however, this item shall be revisted with each subsequent Fire Certificate of Occupancy inspection to determine if the duct work remians in good repair; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.