

## Legislation Details (With Text)

| File #:        | RL⊦<br>257  | FCO 15- Version: 2                         |               |              |        |
|----------------|---|--|---------------|--------------|--------|
| Туре:          |   | olution LH Fire C of O OR<br>rection Order | Status:       | Passed       |        |
|                |   |  | In control:   | City Council |        |
|                |   |  | Final action: | 11/4/2015    |        |
| Title:         | Appeal of Bill Huepenbecker, on behalf of RiverCentre, to a Fire Inspection Correction Notice at 150 KELLOGG BOULEVARD WEST.  |  |               |              |        |
| Sponsors:      | Dave Thune  |  |               |              |        |
| Indexes:       | Fire C of O Letter, Ward - 2  |  |               |              |        |
| Code sections: |   |  |               |              |        |
| Attachments:   | 1. 150 Kellogg Blvd W.appeal.9-24-15, 2. 150 Kellogg Blvd W.appea-budget and blue printl.9-24-15, 3. 150 Kellogg Bvd W.Aerial Map.10-6-15, 4. 150 Kellogg Blvd W.Huepenbecker Ltr.10-9-15 |  |               |              |        |
| Date           | Ver.  | Action By                                  | Ac            | tion         | Result |
| 11/5/2015      | 2   | Mayor's Office                             | Si            | gned         |        |
| 11/4/2015      | 2   | City Council                               | A             | dopted       | Pass   |
| 10/6/2015      | 1   | Legislative Hearings                       | R             | eferred      |        |

Appeal of Bill Huepenbecker, on behalf of RiverCentre, to a Fire Inspection Correction Notice at 150 KELLOGG BOULEVARD WEST.

WHEREAS, in the matter of the Appeal of Bill Huepenbecker, on behalf of RiverCentre, to a Fire Inspection Correction Notice at 150 KELLOGG BOULEVARD WEST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal on the southeast stairwell with the following conditions: standpipe relocate to the south side of the ramp, labeled; exit signs removed; stairwell continued to be blocked and maintained structurally sound; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.