



Legislation Details (With Text)

File #: RLH FCO 15- 344 **Version:** 2

Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed

In control: City Council

Final action: 2/17/2016

Title: Appeal of Jeff & Judy Otto to a Fire Inspection Correction Notice at 391 TOPPING STREET.

Sponsors: Dai Thao

Indexes: Fire C of O Letter, Ward - 1

Code sections:

Attachments: 1. 391 Topping Street Appeal 12-10-15, 2. 391 Topping St.Photos.12-3-15, 3. 391 Topping St.Appeal letter.12-22-15, 4. 391 Topping St.Otto email.12-23-15, 5. 391 Topping St.DSI letter from 1991 to Otto.attached 12-28-15, 6. 391 Topping St.Otto Ltr.12-28-15, 7. 391 Topping St.Email Cervantes.1-11-16, 8. 391 Topping St.Owner Materials.1-19-16, 9. 391 Topping St.Otto-EnglemanLtr.1-22-16

Date	Ver.	Action By	Action	Result
2/23/2016	2	Mayor's Office	Signed	
2/17/2016	2	City Council	Adopted	Pass
1/19/2016	1	Legislative Hearings	Referred	
12/22/2015	1	Legislative Hearings	Laid Over	

Appeal of Jeff & Judy Otto to a Fire Inspection Correction Notice at 391 TOPPING STREET.

AMENDED 2/17/16

WHEREAS, in the matter of the Appeal of Jeff & Judy Otto to a Fire Inspection Correction Notice at 391 TOPPING STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal and grant the following extensions:

March 1 - reduce pallets to 14 ft high;

April 1 - reduce pallets to 12 ft high;

May 1, reduce pallets to 10 ft high;

July 1 - the pallets may be stored in rows of two but there must be a separation between rows of 6 ft; and

July 1 - repair the roof; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.