



Legislation Details (With Text)

File #: RLH FCO 17- **Version:** 2
42

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 5/17/2017

Title: Appeal of Graham M. Butler, Attorney, on behalf of William J. Uhlenkott, to a Fire Inspection Correction Notice at 529 PORTLAND AVENUE.

Sponsors: Dai Thao

Indexes: Fire C of O Letter, Ward - 1

Code sections:

Attachments: 1. 529 Portland Ave.appeal.4-14-17, 2. 529 Portland Ave.Photos.3-31-17 reload 4-17-17.pdf, 3. 529 Portland Ave.Photos.4-17-17.pdf, 4. 529 Portland Ave.Butler Ltr.4-27-17.pdf

Date	Ver.	Action By	Action	Result
5/19/2017	2	Mayor's Office	Signed	
5/17/2017	2	City Council	Adopted	Pass
4/25/2017	1	Legislative Hearings	Referred	

Appeal of Graham M. Butler, Attorney, on behalf of William J. Uhlenkott, to a Fire Inspection Correction Notice at 529 PORTLAND AVENUE.

WHEREAS, in the matter of the Appeal of Graham M. Butler, Attorney, on behalf of William J. Uhlenkott, to a Fire Inspection Correction Notice at 529 PORTLAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant deadlines for the following: 1) grant 30 days to remove accumulation of exterior storage (buckets, recycle bins, tarps, pallets, furniture, buffet, and pots); 2) grant 30 days to remove materials from top shelf/top of cabinets to determine if there is sufficient clearance for the sprinkler heads; if there is less than 18 inches clearance, grant 60 days to remove the storage or rebuild; 3) will allow exterior storage of bricks during this construction season (leftover bricks cannot be stored outside); and 4) remove temporary structure/tent and associated storage within 60 days; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.