



## Legislation Details (With Text)

**File #:** RLH FCO 17- 102 **Version:** 2

**Type:** Resolution LH Fire C of O OR Correction Order **Status:** Passed

**In control:** City Council

**Final action:** 7/19/2017

**Title:** Appeal of Catherine Breier, President of Property Solutions and Services, managing agent for Liberty Plaza, to a Fire Inspection Correction Notice at 295 WESTERN AVENUE NORTH, Townhouses A through J.

**Sponsors:** Dai Thao

**Indexes:** Fire C of O Letter, Ward - 1

**Code sections:**

**Attachments:** 1. 295 Western Ave N.appeal.6-21-17, 2. 415 Marshall Ave-295 Western Ave-279 Western Ave.chain emails.6-26-17.pdf, 3. 295 Western Ave A-J.Breier Ltr.6-30-17.pdf

| Date      | Ver. | Action By            | Action   | Result |
|-----------|------|----------------------|----------|--------|
| 7/24/2017 | 2    | Mayor's Office       | Signed   |        |
| 7/19/2017 | 2    | City Council         | Adopted  | Pass   |
| 6/27/2017 | 1    | Legislative Hearings | Referred |        |

Appeal of Catherine Breier, President of Property Solutions and Services, managing agent for Liberty Plaza, to a Fire Inspection Correction Notice at 295 WESTERN AVENUE NORTH, Townhouses A through J.

WHEREAS, in the matter of the Appeal of Catherine Breier, President of Property Solutions and Services, managing agent for Liberty Plaza, to a Fire Inspection Correction Notice at 295 WESTERN AVENUE NORTH, Townhouses A through J, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal on the carbon monoxide alarm detectors as there is no carbon monoxide-emitting equipment on site; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.