



Legislation Details (With Text)

File #: RLH FCO 17- 103 **Version:** 2

Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed

In control: City Council

Final action: 7/19/2017

Title: Appeal of Catherine Breier, President of Property Solutions and Services, managing agent for Liberty Plaza, to a Fire Inspection Correction Notice at 279 WESTERN AVENUE NORTH, Townhouses A through L.

Sponsors: Dai Thao

Indexes: Fire C of O Letter, Ward - 1

Code sections:

Attachments: 1. 279 Western Ave N.appeal.6-21-17, 2. 415 Marshall Ave-295 Western Ave-279 Western Ave.chain emails.6-26-17.pdf, 3. 279 Western Ave A-L.Breier Ltr.6-30-17.pdf

Date	Ver.	Action By	Action	Result
7/24/2017	2	Mayor's Office	Signed	
7/19/2017	2	City Council	Adopted	Pass
6/27/2017	1	Legislative Hearings	Referred	

Appeal of Catherine Breier, President of Property Solutions and Services, managing agent for Liberty Plaza, to a Fire Inspection Correction Notice at 279 WESTERN AVENUE NORTH, Townhouses A through L.

WHEREAS, in the matter of the Appeal of Catherine Breier, President of Property Solutions and Services, managing agent for Liberty Plaza, to a Fire Inspection Correction Notice at 279 Western Avenue North, Townhouses A through L, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal on the carbon monoxide alarm detectors, as there is no carbon monoxide-emitting equipment on site, and deny the appeal on the blocked egress; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.