

## City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

## Legislation Details (With Text)

File #: RLH FCO 18- Version: 2

26

Type: Resolution LH Fire C of O OR Status: Passed

Correction Order

In control: City Council

**Final action:** 3/28/2018

Title: Appeal of Heidi Schwarze, Unilev Management Corp o/b/o Bureau of Alcohol, Tobacco and Firearms,

to a Fire Inspection Correction Notice at 30 SEVENTH STREET EAST.

**Sponsors:** Rebecca Noecker

Indexes: Fire C of O Letter, Ward - 2

Code sections:

Attachments: 1. 30 Seventh St E.St.Appeal.02-21-2018, 2. 30 Seventh St E.Schwarze Ltr.2-28-18.pdf

Date	Ver.	Action By	Action	Result
4/3/2018	2	Mayor's Office	Signed	
3/28/2018	2	City Council	Adopted	Pass
2/27/2018	1	Legislative Hearings	Referred	

Appeal of Heidi Schwarze, Unilev Management Corp o/b/o Bureau of Alcohol, Tobacco and Firearms, to a Fire Inspection Correction Notice at 30 SEVENTH STREET EAST.

WHEREAS, in the matter of the Appeal of Heidi Schwarze, Unilev Management Corp o/b/o Bureau of Alcohol, Tobacco and Firearms to a Fire Inspection Correction Notice, at 30 SEVENTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal if the 3 conditions listed below pertaining to the interview room are in compliance by April 9:

- 1) quick response sprinklers;
- 2) automatic door lock release in the event of alarm condition;
- 3) automatic smoke detectors within room tied to alarm system; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.