



Legislation Details (With Text)

File #: Ord 18-58 **Version:** 1

Type: Ordinance **Status:** Passed

In control: City Council

Final action: 12/12/2018

Title: Amending Chapter 94 of the Legislative Code pertaining to meters, settings, and cable installations.

Sponsors: Amy Brendmoen

Indexes:

Code sections:

Attachments: 1. Proposed Ordinance, 2. Code Changes - Redline Form, 3. BWC Resolution #18-1701

Date	Ver.	Action By	Action	Result
12/17/2018	1	Mayor's Office	Signed	
12/12/2018	1	City Council	Adopted	Pass
12/5/2018	1	City Council	Public Hearing Closed; Laid Over to Fourth Reading/Final Adoption	Pass
11/7/2018	1	City Council	Laid Over to Third Reading/Public Hearing	
10/24/2018	1	City Council	Laid Over to Second Reading	

Amending Chapter 94 of the Legislative Code pertaining to meters, settings, and cable installations.

THE COUNCIL OF THE CITY OF SAINT PAUL DOES ORDAIN:

SECTION 1

Section 94.04 of the Saint Paul Legislative Code is hereby amended to read as follows:

Chapter 94. - Interior Work

Sec. 94.04. - Meters, settings, cable installation.

- (a) The meter setting shall include the water meter, the meter valves and check valve when required, installed in accordance with meter setting standards of the water utility. The normal setting from the centerline of the meter spuds to the wall shall not be less than eight (8) inches for one-inch and smaller meters, or closer than ten (10) inches for two-inch meters. The height above the floor in all instances shall not be less than twelve (12) inches or more than forty-eight (48) inches except by special permission.
- (b) Piping and materials within the meter setting between the meter valves and at least one foot of the vertical riser shall be type K copper or lead free brass. Copper materials used before the meter shall be brazed or flared. The meter setting and metallic portion of the vertical riser shall be strong and securely attached to an adjacent wall to prevent sagging, swaying or undue vibration. On new services or renewals, the meter shall in all cases be set above the floor.
- (c) Large meters may be set directly on the floor when their weight cannot otherwise be properly supported. Where the owner requests a remote meter reading device, the owner or owner's

representative shall install cable from the meter to the proposed remote meter reading device location. Cable installation and remote meter reading device location shall conform to water utility standards. Cable shall be furnished in sufficient length to facilitate connection by the water utility at the meter and the remote meter reading device.

SECTION 2

This Ordinance shall take effect and be in force thirty (30) days following its passage, approval and publication.