



Legislation Details (With Text)

File #: RLH OA 20-6 **Version:** 2
Type: Resolution LH Other Appeal **Status:** Passed
Type
In control: City Council
Final action: 7/8/2020
Title: Appeal of Erandi Lindsey to an e-mail from the Department of Safety and Inspections (DSI) dated 5/13/2020 regarding a Septic System at 2108 SKYWAY DRIVE.
Sponsors: Jane L. Prince
Indexes: Ward - 7
Code sections:
Attachments: 1. 2108 Skyway Dr.appeal.6-5-20, 2. 2108 Skwyway Dr.Lindsey Ltr.6-24-20.pdf

Date	Ver.	Action By	Action	Result
7/14/2020	2	Mayor's Office	Signed	
7/8/2020	2	City Council	Adopted	Pass
6/16/2020	1	Legislative Hearings		

Appeal of Erandi Lindsey to an e-mail from the Department of Safety and Inspections (DSI) dated 5/13/2020 regarding a Septic System at 2108 SKYWAY DRIVE.

WHEREAS, in the matter of the Appeal of Erandi Lindsey to an e-mail from the Department of Safety and Inspections (DSI) dated 5/13/2020 regarding a septic system at 2108 Skyway Drive, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 25 ft variance of the 75 ft setback requirement for separation of the septic tank and well; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.