

City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

Legislation Details (With Text)

File #: ALH 10-101 Version: 1

Type: Appeal-Legislative Hearing Status: Filed

In control: Legislative Hearings

Final action: 9/7/2010

Title: Appeal of Renewal by Anderson on behalf of Elysse Duffy to the denial of a building permit to replace

egress windows for property at 2086 Princeton Avenue (Ward 3)

Sponsors: Pat Harris

Indexes: Ward - 3, Windows

Code sections:

Attachments: 1. 2086 Princeton Ave. Appeal. 9-14-10.pdf

Date	Ver.	Action By	Action	Result
9/7/2010	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Renewal by Anderson on behalf of Elysse Duffy to the denial of a building permit to replace egress windows for property at 2086 Princeton Avenue (Ward 3)

2086 Princeton Avenue

We are appealing 2 replacement windows that will not comply with the height requirement stated in the egress window policy. Windows, at their current dimensions will comply with policy requirements in width and overall glazed area. Please approve.

August 31, 2010 Egress Window Non-Compliance Determination.

September 7, 2010

Granted without hearing.

Grant a 2-inch variance on the openable height of two double hung replacement egress windows.

[Enter the target date for this item to be introduced to Council]