

City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

Legislation Details (With Text)

File #: ALH 10-104 Version: 1

Type: Appeal-Legislative Hearing Status: Filed

In control: Legislative Hearings

Final action: 9/7/2010

Title: Appeal of Jason Nordhougen to a Certificate of Occupancy Deficiency List for property at 1023

Bradley Street (Ward 5)

Sponsors: Lee Helgen

Indexes: Fire C of O Letter, Ward - 5, Windows

Code sections:

Attachments: 1. 1023 Bradley St.Appeal.9-7-10.pdf, 2. 1023 Bradley St.Fire C of O Ltr.7-16-10

Date	Ver.	Action By	Action	Result
9/7/2010	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Jason Nordhougen to a Certificate of Occupancy Deficiency List for property at <u>1023 Bradley Street</u> (Ward 5)

1023 Bradley Street

Window meets total minimum size but is approximately 4" short of opening height. It is 7" wider than the required minimum.

August 16, 2010

September 7, 2010

Grant without hearing.

Grant a 4-inch variance on the openable height of the egress window in the west bedroom.

[Enter the target date for this item to be introduced to Council]