

## City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

## Legislation Details (With Text)

File #: ALH 10-305 Version: 1

Type: Appeal-Legislative Hearing Status: Filed

In control: Legislative Hearings

**Final action:** 11/2/2010

Title: Appeal of Ramsey County Public Health on behalf of Ruby Fair to an Egress Window Non-

Compliance Determination at 726 Cook Avenue East.

**Sponsors:** Dan Bostrom

Indexes: Ward - 6, Windows

**Code sections:** 

Attachments: 1. 726 Cook Ave.Appeal.10-22-10.pdf

Date	Ver.	Action By	Action	Result
11/2/2010	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Ramsey County Public Health on behalf of Ruby Fair to an Egress Window Non-Compliance Determination at 726 Cook Avenue East.

726 Cook Avenue East

Egress windows.

October 22, 2010

No hearing necessary, as only windows under appeal.

Grant variance of 2" in openable height for double hung window with egress opening of 19.2" width and 22" height

Grant variance of 4" in openable height and 1" in openable width for windows with egress opening of 19.3" width and 20" height