

## City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

## Legislation Details (With Text)

File #: ALH 10-363 Version: 1

Type: Appeal-Legislative Hearing Status: Filed

In control: Legislative Hearings

**Final action:** 11/16/2010

Title: Appeal of Linda Bell to a Egress Window Non-Compliance Determination at 1036 DALE STREET

NORTH.

Sponsors: Lee Helgen

Indexes: Ward - 5, Windows

**Code sections:** 

Attachments: 1. 1036 Dale.appeal.11-5-10.pdf

Date	Ver.	Action By	Action	Result
11/16/2010	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Linda Bell to a Egress Window Non-Compliance Determination at 1036 DALE STREET NORTH.

## 1036 Dale Street North

The failed height dimension can be reduced from 8 inches to 7 inches with little expense. To meet the city requirements, the homeowner will need to pay for full frame removal, re-rout the outlet wires by a licensed electrician, rebuild the exterior siding and brick mould, and rebuild and stain/polyurethane the new interior woodwork. Total cost to homeowner will be \$1,045 above the standard window cost.

October 5, 2010

[Enter Summary Here]