

## City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

## Legislation Details (With Text)

File #: ALH 10-433 Version: 1

Type: Appeal-Legislative Hearing Status: Filed

In control: Legislative Hearings

**Final action:** 11/30/2010

Title: Appeal of Progressive Construction Homebuilding on behalf of Bob and Lynn Connolly to an Egress

Window Non-Compliance Determination at 105 ROSE AVENUE WEST.

**Sponsors:** Lee Helgen

Indexes: Ward - 5, Windows

Code sections:

Attachments: 1. 105 Rose.appeal.11-30-10.pdf

Date	Ver.	Action By	Action	Result
11/30/2010	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Progressive Construction Homebuilding on behalf of Bob and Lynn Connolly to an Egress Window Non-Compliance Determination at 105 ROSE AVENUE WEST.

Egress windows: size, change dimensions, length, and height. I have the size I need, but I have 28 width and 20 7/8 height. If we reverse the height and width, it will pass.

November 15, 2010

No hearing necessary, recommend variance.