

Legislation Details (With Text)

File #:	ALH 10-504	Version:	1
Type:	Appeal-Legislative Hearing	Status:	Filed
		In control:	Legislative Hearings
		Final action:	12/14/2010
Title:	Appeal of Pat Mentone to a Fire Inspection Correction Notice at 2398 STEWART AVENUE.		
Sponsors:	Pat Harris		
Indexes:	Ward - 3, Windows		
Code sections:			
Attachments:	1. 2398 Stewart.appeal.12-14-10.pdf, 2. 2398 Stewart Ave.PC ltr.12-14-10.pdf		

Date	Ver.	Action By	Action	Result
12/14/2010	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Pat Mentone to a Fire Inspection Correction Notice at 2398 STEWART AVENUE.

Building is approx 100 yrs old. Glazed area is 7.4 sq ft min height is 1.5 inches undersized. Width is ok. This would be a major expense to change!

November 19, 2010

No hearing Necessary. Recommend grant of a variance.