

Legislation Details (With Text)

File #:	ALH 10-530 Version:	1		
Туре:	Appeal-Legislative Hearing	g Status: Filed	Filed	
		In control: Legislative Hearings		
		Final action: 12/14/2010		
Title:	Appeal of Donald Moeller, on behalf of Henry Hite to a Fire Inspection Correction Notice at 645 WHEELOCK PARKWAY WEST.			
Sponsors:	Lee Helgen			
Indexes:	Fire C of O Letter, Ward - 5, Windows			
Code sections:				
Attachments:	1. 645 Wheelock.Appeal.12-14-10.pdf, 2. 645 Wheelock Pkwy W.PC ltr 12-14-10.pdf			
Date	Ver. Action By	Action	Result	
12/14/2010	1 Legislative Hearings	Referred Under Master Res	olution	

Appeal of Donald Moeller, on behalf of Henry Hite to a Fire Inspection Correction Notice at 645 WHEELOCK PARKWAY WEST.

Appealing Item 2 on deficiency list for the following reasons: 1) this room (SW bdrm) has four windows that open to at least 16" high and 39" wide. The height from floor is 42". We feel that to alter these windows for the sale of 4" in height is unreasonable. 2) The intigrety of the outsie of the home (siding, trim, and stonework) would also be jeopardized.

November 24, 2010

No hearing Necessary. Recommend grant of a variance.