

Legislation Details (With Text)

-				
File #:	ALH 10-559 Version:	1		
Туре:	Appeal-Legislative Hearing	g Status:	Filed	
		In control:	Legislative Hearings	
		Final action:	12/21/2010	
Title:	Appeal of Yemane Mebrahtu to a Fire Inspection Correction Notice at 849 OTTO AVENUE.			
Sponsors:	Dave Thune			
Indexes:	Fire C of O Letter, Ward - 2, Windows			
Code sections:				
Attachments:	1. 849 Otto.appeal.12-21-10.pdf, 2. 849 Otto Ave.PC Ltr.12-21-10.pdf			
Date	Ver. Action By	Act	ion	Result
12/21/2010	1 Legislative Hearings			

Appeal of Yemane Mebrahtu to a Fire Inspection Correction Notice at 849 OTTO AVENUE.

It is a townhouse with 11 units. They were built in 1982. They all have the same safety footage and size. 849 is one of them. The windows conditions are good, except they are not as big as required because at the time they were built the requirement was not in affect.

December 15, 2010

No hearing necessary. Recommend variance on egress window dimensions.