

## Legislation Details (With Text)

Date	Ver. Action By	Acti	on	Result
Attachments:	1. 1661 Hubbard.appeal.2-22-11.pdf, 2. 1661 Hubbard Ave.McMahon Ltr 3-8-11.pdf			
Code sections:				
Indexes:	Fire C of O Letter, Ward - 4, Windows			
Sponsors:	Russ Stark			
Title:	Appeal of Michael McMahon to a Fire Inspection Correction Notice at 1661 Hubbard Avenue.			
		Final action:	3/8/2011	
		In control:	Legislative Hearings	
Туре:	Appeal-Legislative Hearing	Status:	Filed	
File #:	ALH 11-330 Version: 1			

3/8/2011 1 Legislative Hearings

Appeal of Michael McMahon to a Fire Inspection Correction Notice at 1661 Hubbard Avenue.

Windows are 7.0 sq ft of glazed area per inspector. Windows upgraded with vinyl windows in past 10 years. 17.5 high & 23.5. There is also a full exit door on 2nd floor. Bungalow style with windows in the dormer.

February 11, 2011

No hearing Necessary. Recommend variance on egress window dimensions.