



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
48

Type: Resolution LH Fire Ordered Windows
Status: Passed
In control: City Council
Final action: 6/1/2011

Title: Appeal of Frank (Francis) Asenbrenner to a Fire Inspection Correction Notice at 1435 BIRMINGHAM STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1435 Birmingham.appeal.3-29-11.pdf, 2. 1435-1437 Birmingham.Asenbrenner Ltr 4-12-11.pdf

Date	Ver.	Action By	Action	Result
7/13/2016	2	Housing & Redevelopment Authority	Adopted	Pass
6/6/2011	2	Mayor's Office	Signed	
4/12/2011	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Frank (Francis) Asenbrenner to a Fire Inspection Correction Notice at 1435 BIRMINGHAM STREET.

See #17 on the attached list. I wish to appeal this item because these are the original windows installed on the home. Also, they are very close to regulation size, only 1/2 inch difference.

March 2, 2011

No hearing necessary. Recommend variance on egress window dimensions.

WHEREAS, in the matter of the appeal of Frank (Francis) Asenbrenner to a Fire Inspection Correction Notice at 1435 BIRMINGHAM STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress bedroom windows in 1435 and 1437; now, therefore, be it

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.